



**INSTITUTE OF CERAMICS
AND BUILDING MATERIALS**

**DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW
DEPARTMENT OF GLASS TECHNOLOGY**

30-702 Cracow, Lipowa 3 Str

phone.: (+48 12) 423 67 77 fax (+48 12) 423 58 36

www.icimb.pl e-mail: info2_krakow@icimb.pl

TESTING CERTIFICATE No. 1873/ICiMB/ST/12

Subject of testing: *Security glazing Pilkington Optilam™ 19,5
with construction described in Test Report No. 158.W.12.AK,
produced by Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Principal Orderer: *Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Type of testing: *Test included verification of security glazing class
according to PN-EN 356: 2000 „Glass in building – Security glazing – Testing
and classification of resistance against manual attack”*

Judgement: *As a results tests was affirmed that security glazing
Pilkington Optilam™ 19,5 produced by Pilkington Polska Sp. z o.o.
complies requirements for class P6B of security glazing*

The basic of judgement: *Test Report No. 158.W.12.AK,
dated 29.11.2012*

Responsible person for the test:

KIEROWNIK
Zakładu Technologii Szkła

mgr inż. Sebastian Sacha

Cracow, date 29.11.2012

This certificate is valid to: 29.11.2014

Director
DYREKTOR ODDZIAŁU

dr inż. Henryk Szelağ