

DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW **DEPARTMENT OF GLASS TECHNOLOGY**

30-702 Cracow, Lipowa 3 Str

phone.: (+48 12) 423 67 77 (+48 12) 257 12 00 fax (+4812) 423 58 36 www.icimb.pl e-mail:info2 krakow@icimb.pl

TESTING CERTIFICATE No. 2096/ICIMB/ST/14

Subject of testing: Laminated safety building glass

Pilkington Optilam TM 8,4

produced by Pilkington Polska Sp. z o.o.

27-600 Sandomierz ul. Portowa 24

Principal Orderer: Pilkington Polska Sp. z o.o.

27-600 Sandomierz ul. Portowa 24

Type of testing: verification of laminated safety glass resistance for pendulum impact according to standard PN-EN 12600: 2004 "Glass in building. Pendulum test. Impact test method and classification for flat glass"

Judgement: Tested laminated safety building glass of type Pilkington Optilam TM 8,4 produced by Pilkington Polska Sp. z o.o. has a strength class under pendulum impact 2/B/2 according to standard PN-EN 12600: 2004

The basic of judgement: Test Report No. 126.W.14.AK

dated 29.10.2014

Responsible person for the test: Zakładu Technologii Azkła

mgr inz. Se pastian Sacha

Cracow, date 29.10.2014

This certificate is valid to: 29.10.2017

Director |

DZIAŁU

dr inż. Pawer Pichniarczyk