



Łukasiewicz

**Instytut Ceramiki
i Materiałów Budowlanych**

**Division of Glass and Building Materials in Krakow
Department of Glass Technology**

ul. Lipowa 3, 30-702 Kraków, Poland
tel. +48 12 423 67 77, info2_krakow@icimb.pl, www.icimb.pl

TESTING CERTIFICATE No. 2391/ICiMB/KT/20

Subject of testing: Pilkington Optilam™ 6,4
laminated safety glass with construction described in Test Report
No. 049.W.20.AK produced by Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24

Principal Orderer: Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24

Type of testing: verification of pendulum body impact resistance
class according to standard PN-EN 12600: 2004 "Glass in building
Pendulum test Impact test method and classification for flat
glass"

Judgement: Pilkington Optilam™ 6,4 laminated safety glass has
2/B/2 pendulum body impact resistance class according to
standard PN-EN 12600: 2004

The basic of judgement: Test Report No. 049.W.20.AK
of 12.05.2020

Responsible person for the test:

Kierownik Zakładu
Technologii Szkła
dr inż. Magda Kosmal

p.o Dyrektor Oddziału Instytutu
mgr inż. Michał Wiczorek

Kraków, date: 12.05.2020

DIRECTOR

This certificate is valid to 12.05.2023

