



INSTITUTE OF CERAMICS
AND BUILDING MATERIALS

DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW
DEPARTMENT OF GLASS TECHNOLOGY

30-702 Cracow, Lipowa 3 Str

phone.: (+48 12) 423 67 77 (+48 12) 257 12 00 fax (+48 12) 423 58 36

www.icimb.pl e-mail: info2_krakow@icimb.pl

TESTING CERTIFICATE No. 2210/ICiMB/ST/17

Subject of testing: *Pilkington Optilam™ 4,4
laminated safety building glass
produced by Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Principal Orderer: *Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Type of testing: *verification of pendulum body impact resistance class
according to standard PN-EN 12600: 2004 „Glass in building. Pendulum test.
Impact test method and classification for flat glass”*

Judgement: *Tested Pilkington Optilam™ 4,4
laminated safety building glass produced by
Pilkington Polska Sp. z o.o.
has 2/B/2 pendulum body impact resistance class
according to standard PN-EN 12600: 2004*

The basic of judgement: *Test Report No. 128.W.17.AK
dated 11.10.2017*

Responsible person for the test:

Z-ca KIEROWNIKA
Zakładu Technologii Szkła

mgr Inż. Anna Balon-Wróbel

Cracow, date 11.10.2017

This certificate is valid to: 11.10.2020

ZASTĘPCA DYREKTORA
ODDZIAŁU

mgr inż. Henryk Szelaż