



INSTITUTE OF CERAMICS
AND BUILDING MATERIALS

DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW
DEPARTMENT OF GLASS TECHNOLOGY

30-702 Cracow, Lipowa 3 Str

phone.: (+48 12) 423 67 77 (+48 12) 257 12 00 fax (+48 12) 423 58 36

www.icimb.pl e-mail: info2_krakow@icimb.pl

TESTING CERTIFICATE No. 2193/ICiMB/ST/17

Subject of testing: *Security glazing Pilkington Optilam™ 7,5
with construction described in Test Report No. 054.W.17.AK,
produced by Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Principal Orderer: *Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Type of testing: *Test included verification of security glazing class
according to PN-EN 356: 2000 „Glass in building – Security glazing
– Testing and classification of resistance against manual attac”*

Judgement: *security glazing Pilkington Optilam™ 7,5
complies requirements for class P4A of security glazing*

The basic of judgement: *Test Report No. 054.W.17.AK,
dated 20.04.2017*

Responsible person for the test:

Z-ca KIEROWNIKA
Zakładu Technologii Szkła

mgr inż. Anna Kozłowska-Wróbel

Cracow, date 20.04.2017

This certificate is valid to: 20.04.2020

Director
ZASTĘPCA DYREKTORA
ODDZIAŁU

dr inż. Henryk Szelaż