



**INSTITUTE OF CERAMICS
AND BUILDING MATERIALS**

**DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW
DEPARTMENT OF GLASS TECHNOLOGY**

30-702 Cracow, Lipowa 3 Str

phone.: (+48 12) 423 67 77 (+48 12) 257 12 00 fax (+48 12) 423 58 36

www.icimb.pl e-mail: info2_krakow@icimb.pl

TESTING CERTIFICATE No. 1927/ICiMB/ST/14

Subject of testing: *Security glazing Pilkington Optilam™ 6,8
with construction described in Test Report No. 025.W.14.AK,
produced by Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Principal Orderer: *Pilkington Polska Sp. z o.o.
27-600 Sandomierz ul. Portowa 24*

Type of testing: *Test included verification of security glazing class
according to PN-EN 356: 2000 „Glass in building – Security glazing
– Testing and classification of resistance against manual attac”*

Judgement: *As a results tests was affirmed that security glazing
Pilkington Optilam™ 6,8 produced by Pilkington Polska Sp. z o.o.
complies requirements for class P2A of security glazing*

The basic of judgement: *Test Report No. 025.W.14.AK,
dated 13.03.2014*

Responsible person for the test:

KIEROWNIK
Zakładu Technologii Szafa
mgr inż. Sebastian Sacha

Cracow, date 13.03.2014

Z-CIA DYREKTORA ODDZIAŁU

dr inż.  Director

This certificate is valid to: 13.03.2017