



**INSTITUTE OF CERAMICS  
AND BUILDING MATERIALS**

**DIVISION OF GLASS AND BUILDING MATERIALS IN CRACOW  
DEPARTMENT OF GLASS TECHNOLOGY**

**30-702 Cracow, Lipowa 3 Str**

phone.: (+48 12) 423 67 77 (+48 12) 257 12 00 fax (+48 12) 423 58 36

www.icimb.pl e-mail: info2\_krakow@icimb.pl

## **TESTING CERTIFICATE No. 1925/ICiMB/ST/14**

**Subject of testing:** *Security glazing Pilkington Optilam™ 7,5  
with construction described in Test Report No. 025.W.14.AK,  
produced by Pilkington Polska Sp. z o.o.  
27-600 Sandomierz ul. Portowa 24*

**Principal Orderer:** *Pilkington Polska Sp. z o.o.  
27-600 Sandomierz ul. Portowa 24*

**Type of testing:** *Test included verification of security glazing class  
according to PN-EN 356: 2000 „Glass in building – Security glazing  
– Testing and classification of resistance against manual attac”*

**Judgement:** *As a results tests was affirmed that security glazing  
Pilkington Optilam™ 7,5 produced by Pilkington Polska Sp. z o.o.  
complies requirements for class P4A of security glazing*

**The basic of judgement:** *Test Report No. 025.W.14.AK,  
dated 13.03.2014*

**Responsible person for the test:**

KIEROWNIK  
Zakładu Technologii Szkła

mgr inż. Sebastian Sacha

Cracow, date 13.03.2014

Z-CIA DYREKTORA ODDZIAŁU

dr inż. Paweł Pichniarczyk  
Director

This certificate is valid to: 13.03.2017