



Prüfzentrum für Bauelemente


Dipl.-Ing. (FH) Rüdiger Müller


Fenster · windows
Rollläden · shutters
Türen + Tore · doors
Fassaden · curtain walling
Baubeschläge · building hardware

SHORT REPORT NR. 17/03-A088-K2

Version 1.en

Laboratory measurement of airborne sound insulation of building elements according to DIN EN ISO 10140-2 : 2010 and rating of the measurement results according to DIN EN ISO 717-1: 2013-06

Applicant	Pilkington IGP Sp. z o.o. Ul. Półnanki 62 30-740 Kraków/Poland
Type	Insulated glass unit
Product designation	10_14_6_14_66.2
Dimension	(w x h) 1230 mm x 1480 mm
Glass construction	Float 10 mm / cavity 14 mm (Ar) / Float 6 mm / cavity 14 mm (Ar) / LSG 66.2 The foil which was used to produce the IG unit is SC+.
Test Report	Test Report Nr. 17/03-A088-B1 Version 1.en of March 30, 2017
Test Result	Weighted sound reduction index R_w  $R_w (C; C_{tr}) = 46 (-1; -3) \text{ dB}$
Validity	Valid for the period of validity of the standards given above


Dipl.-Ing. Matthias Demmel
Head of Notified Test Body



Stephanskirchen
30.03.2017


Dipl.-Ing.(FH) Michael Ewald
Responsible Official

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 674947 0
Telefax +49 (0) 80 36 / 674947 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Sparkasse Rosenheim-Bad Aibling
IBAN: DE88 7115 0000 0500 5567 41
SWIFT-BIC: BYLADEM1ROS
Steuer-Nr.: 156/172/13009
USt-IdNr.: DE245353602

